



QPS Evaluation Services Inc
Testing, Certification and Field Evaluation Body
Accredited in Canada, the USA, and Internationally

File
LR1498

CERTIFICATE OF COMPLIANCE
(ISO TYPE 3 CERTIFICATION SYSTEM)

Issued to	I-care Reliability Inc
Address	7676 Hillmont Street, Suite 290AA, Houston, TX 77040. USA
Project Number	LR1498-1
Product	Battery powered wireless vibration monitor
Model Number	WM(a)1212112(b)
Ratings	3V, Battery powered
Markings	Class 1, Zone 0, AEx ia IIC T3/T4 Ex ia IIC T3/T4 Ga Ta = -20°C to +73°C (T4) Ta = -20°C to +85°C (T3)
Applicable Standards	CSA C22.2 No. 60079-0:15, CSA C22.2 No. 60079-11:14, CSA-C22.2 No.61010-1-12, Edition 3, ISA 60079-0 (12.00.01) -2013, ISA 60079-11 (12.02.01) -2014, UL-61010-1 (82.02.01), Edition 3
Factory/Manufacturing Location	Same as above

Statement of Compliance: The product(s) identified in this Certificate and described in the Report covered under the above referenced project number have been investigated and found to be in compliance with the relevant requirements of the above referenced standard(s). As such, they are eligible to bear the QPS Certification Mark shown below, in accordance with the provisions of QPS's Service Agreement.



Issued By: Dave Adams, P.Eng.

Signature: 

Date: August 31, 2018