



Certificate of Compliance

Certificate: 80211151 **Master Contract:** 304650
Project: 80222601 **Date Issued:** 2024-09-24
Issued to: I-care SRL
Rue Descartes 18
Mons, Walloon Brabant 7000
Belgium
Attention: Ulrich Weinsdoerfer

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Oong Lee
Oong Lee

PRODUCTS

Class 2252 06 PROCESS CONTROL EQUIPMENT - Process Control Equipment

Class 2252 86 PROCESS CONTROL EQUIPMENT - Certified to US Standards

Accelerometer & Vibration Sensor, Wi-care 130

Model(s)	Battery (VDC)	Ambient Temp. Range
WM51033114103, WM50033114107, WM51033114102, WM51033144101	3.6	-20 °C to +70 °C
WM50033114108	3.6	-20 °C to +85 °C
WM51033134101	3.0	-20 °C to +70 °C

APPLICABLE REQUIREMENTS

CSA C22.2 No. 61010-1-12, UPD1:2015, UPD2:2016, AMD1:2018, UPD3:2023 - Safety requirements for electrical equipment for



Certificate: 80211151

Master Contract: 304650

Project: 80222601

Date Issued: 2024-09-24

measurement, control, and laboratory use — Part 1: General requirements - Third Edition; Update No. 1: July 2015; Update No. 2: April 2016; Update No. 3: June 2023

UL 61010-1 3rd ed (Rev. Jun 6, 2023) - UL Standard for Safety Electrical Equipment For Measurement, Control, and Laboratory Use; Part 1: General Requirements - Third Edition; Reprint with Revisions Through and Including JUNE 6, 2023

Conditions Of Acceptability

1. Battery replacement shall be done by the manufacturer or authorized distributors only.

Markings

The manufacturer is required to apply the following markings:




- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.


Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

The following markings appear on the product:

1. Submitter's identification (company name and/or file number and/or registered tradename);
2. Marking on the unit that indicates the manufacturing location if the equipment is manufactured at more than one factory location;
3. Model designation;
4. Date of manufacture: Month and year of manufacture or date code. If a serial number is used instead of date of manufacture, a record of serial numbers shall be kept traceable to date of manufacture. (Not related to date of sale);
5. The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US, or with

adjacent indicator 'US' for US only, or without either indicator for Canada only:  , or  , or  ;

6. Symbol #14 “ ,”



Certificate: 80211151

Project: 80222601

Master Contract: 304650

Date Issued: 2024-09-24

Notes:

Products certified under Class(es) C225206, C225286 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 80211151

Master Contract: 304650

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80222601	2024-09-24	Variation to CSA 80211151 for following modifications: 1. New battery type, Saft M52 EX SV ---> forming a new model WM51033134101 2. New battery type, Tadiran SL-2770 ---> forming a new model WM51033144101 3. Addition of WM51033114102 which is identical to WM51033114103. 4. Addition of WM50033114108 for 85 degC ambient.
80211151	2024-07-09	Original cCSAus certification of vibration sensor series Wi-care 130 Ex ia models WM51033114103 and WM50033114107