



Certificate of Compliance

Certificate: 80218472

Master Contract: 304650

Project: 80218472

Date Issued: August 22, 2025

Issued To: I-care SRL
Rue Descartes 18
Mons, Walloon Brabant,
7000
Belgium

Attention: Ulrich Weinsdoerfer

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by:

Oong Lee

PRODUCTS

CLASS - C225802 - PROCESS CONTROL EQUIPMENT For Hazardous Locations

CLASS - C225882 - PROCESS CONTROL EQUIPMENT For Hazardous Locations - Certified to US Standards

Class I, Division 2, Group A, B, C, D

Ex eb mb IIC T4 Gb

Class I, Zone 1, AEx eb mb IIC T4 Gb

Wireless Gateway GW900-4G-US Ex, Models WG150161H-02, rated for 100 – 240 Vac, 50/60 Hz, 1.8 W and WG150161L-02, rated for 24 Vdc, 1.8 W; Temperature class T4; Ambient: $-15^{\circ}\text{C} \leq T_{\text{amb}} \leq 60^{\circ}\text{C}$;

Conditions of Acceptability:

1. Under certain extreme circumstances, the non-metallic parts incorporated in the enclosure of this equipment may generate an ignition-capable level of electrostatic charge. Therefore, the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces. In addition, the equipment shall only be cleaned with a damp cloth.



Certificate: 80218472
Project: 80218472

Master Contract: 304650
Date Issued: August 22, 2025

2. This equipment shall be installed where the risk of damage to the equipment due to impact is considered to be low.
3. The prospective short circuit current shall be less than 1500 A for AC supply and 100 A for DC supply.
4. The product was tested in a branch circuit protected by a 20 A circuit breaker. Additional evaluation shall be conducted if a higher protector is to be used in the end system

APPLICABLE REQUIREMENTS

CSA C22.2 No. 62368-1:19	Audio/Video, Information and Communication Technology Equipment – Part 1: Safety Requirements
CSA C22.2 No. 213:17, Updates 1 & 2 & 3 (R2022)	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CSA C22.2 No. 60079-0:19 (R2024)	Explosive Atmospheres - Part 0: Equipment - General requirements
CSA C22.2 No. 60079-7:16 (R2021)	Explosive Atmospheres - Part 7: Equipment protection by increased safety “e”
CSA C22.2 No. 60079-18:16 + AMD1:2018 (R2021)	Explosive Atmospheres – Part 18: Equipment Protection by Encapsulation “m”
UL 62368-1-2019	Audio/Video, Information and Communication Technology Equipment – Part 1: Safety Requirements
UL 121201-2021	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
UL 60079-0-2024	Explosive Atmospheres - Part 0: Equipment - General requirements
UL 60079-7-2021	Explosive Atmospheres - Part 7: Equipment protection by increased safety “e”
UL 60079-18-2023	Explosive Atmospheres – Part 18: Equipment Protection by Encapsulation “m”

MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

- The CSA Mark with adjacent C_US qualifiers
- Manufacturer



Certificate: 80218472
Project: 80218472

Master Contract: 304650
Date Issued: August 22, 2025

-
- Model designation
 - CSA certificate number : CSA 25CA80218472X
 - Serial number and a date code that is traceable to the year of manufacture
 - The hazardous location designation (See 'PRODUCTS' section)
 - The temperature class (See 'PRODUCTS' section)
 - The ambient temperature range (See 'PRODUCTS' section)
 - The following warnings (These warnings are also marked in French):
WARNING – READ MANUAL
WARNING – POTENTIAL ELECTROSTATIC CHARGING HAZARD

Notes:

Products certified under Class C225802, C225882 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

